

Children’s Center Sampling Results Key

Sample Number	Date of Sample	Annex or Main Building	Room number	Sink or Drinking Fountain	First Draw or After Flush	Results in ppb^	Foran Results ppb	Post-replacement
CDC-01-DW-01	10/14/16	Main Building	107	Drinking Fountain	First Draw	ND	11.0	2.0
CDC-01-DW-02	10/14/16	Main Building	107	Drinking Fountain	After Flush	ND	n/a	0.13
CDC-01-DW-03	10/14/16	Annex	Exterior	Drinking Fountain	First Draw	0.40	ND	
CDC-01-DW-04	10/14/16	Annex	Exterior	Drinking Fountain	After Flush	0.66	n/a	
CDC-M-5-01	11/10/16	Main Building	108	Sink	First Draw	.91	n/a	
CDC-M-DF-02	11/10/16	Main Building	108	Drinking Fountain	First Draw	6.6	3.9	n/a
CDC-M-5-03	11/10/16	Main Building	108	Sink (East)	First Draw	.74	n/a	
CDC-M-5-04	11/10/16	Main Building	107	Sink (West)	First Draw	.91	n/a	
CDC-M-5-05	11/10/16	Main Building	107	Sink (East)	First Draw	.66	n/a	
CDC-M-5-06	11/10/16	Main Building	105	Sink (North)	First Draw	.72	n/a	
CDC-M-5-07	11/10/16	Main Building	105	Sink (South)	First Draw	.79	n/a	
CDC-M-DF-08	11/10/16	Main Building	105	Drinking Fountain	First Draw	.99	0.54	
CDC-M-5-09	11/10/16	Main Building	104	Sink	First Draw	.59	n/a	
CDC-M-DF-10	11/10/16	Main Building	104	Drinking Fountain	First Draw	5.3	0.91	4.1
		Main Building	104	Drinking Fountain	After flush	n/a	n/a	0.24
CDC-M-DF-11	11/10/16	Main Building	106	Sink	First Draw	2.0	n/a	
CDC-M-5-12	11/10/16	Main Building	103	Sink	First Draw	ND	n/a	
CDC-AN-DF-13	11/10/16	Annex	1	Drinking Fountain	First Draw	ND	ND	
CDC-AN-5-14	11/10/16	Annex	Hallway	Sink	First Draw	.49	n/a	
CDC-AN-DF-15	11/10/16	Annex	2	Drinking Fountain	First Draw	ND	ND	
CDC-AN-5-16	11/10/16	Annex	3	Sink	First Draw	2.0	n/a	

CDC-AN-5-17	11/10/16	Annex	Exterior	Sink	First Draw	.24	n/a	
CDC-M-DF-18	11/10/16	Main Building	Exterior - North	Drinking Fountain	First Draw	1.8	n/a	

\*Sink in Room 106 and Eastern Sink in Annex Hallway were not sampled because water was visible in the sink indicating it had been operated.

^ ppb = parts per billion or  $\mu\text{g/L}$  of water